



BRACEWELL ENGINEERING, INC.

155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037

(669) 258-5820 FAX (408) 498-7045

www.bracewellengineering.com

April 14, 2026

District Engineer
State Water Resources Control Board-Division of Drinking Water
850 Marina Bay Parkway, Building P, 2nd Floor
Richmond, CA 94804

Re: March 2026 Monthly Report to the Office of Drinking Water
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear District Engineer:

Attached are the following:

1. Monitoring Report
 2. Lab Results
 3. Coliform Reporting Form
 4. Surface Water Reports
 5. Quarterly Report for Disinfectant Residuals Compliance
 6. Quarterly TTHM & HAA5 Reports for Disinfection Byproducts Compliance
- The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
 - Chlorine residuals were maintained as required.
 - The minimum Disinfection CT ratio was 4.2 for a DDW required 1- log removal for Giardia.
 - The quarterly disinfection byproducts monitoring was completed and the TTHM running annual average of 50.8 ug/L was in compliance with its MCL of 80 ug/L and the HAA5 running annual average of 45.8 ug/L was in compliance with its MCL of 60 ug/L.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,
BRACEWELL ENGINEERING, INC.

Alan Bracewell
Staff Engineer

LHW

March

La Honda Water System

| CALIBRATION TURBIDITY | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
|-----------------------|---|-----------|---------|-----------|-----------|----------|------------------|------|------|---------|
| | Alpine Creek - Raw Water | AA20902 | 3/26/26 | Pass | | | | | | |
| | Treated Water | AA20903 | 3/26/26 | Pass | | | | | | |
| CHLORINE RESIDUAL | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | APN 083-240-070 (No site address) | AA21533 | 3/16/26 | 2.21 | mg/L | | SM 4500-CI G | 0.02 | 0.02 | Routine |
| COLIFORM MPN | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | Alpine Creek - Raw Water | AA21532 | 3/16/26 | 185.0 | MPN/100mL | | SM9223B-18 (MPN) | 1.0 | 1.0 | Other |
| COLIFORM PA | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | APN 083-240-070 (No site address) | AA21533 | 3/16/26 | A | P/A | | SM9223B-18 | | | Routine |
| E COLI MPN | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | Alpine Creek - Raw Water | AA21532 | 3/16/26 | 38.3 | MPN/100mL | | SM9223B-18 (MPN) | 1.0 | 1.0 | Other |
| E COLI PA | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | APN 083-240-070 (No site address) | AA21533 | 3/16/26 | A | P/A | | SM9223B-18 | | | Routine |
| TOTAL HAA5 | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | Old Chlorination Station- Sam McDonald Park | AA21534 | 3/16/26 | 48 | µg/L | 60 | EPA 552.2 | | | |
| TTHM | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | Old Chlorination Station- Sam McDonald Park | AA21534 | 3/16/26 | 44 | µg/L | 80 | EPA 551.1 | | | |
| UV254 PERF | SAMPLE POINT | SAMPLE ID | DATE | RESULT | UNIT | LIMIT | METHOD | DL | RL | TYPE |
| | Alpine Creek - Raw Water | AA21681 | 3/16/26 | 0.070 | 1/cm | | SM 5910B | | | |
| | Alpine Creek - Raw Water | AA21724 | 3/26/26 | 0.100 | 1/cm | | SM 5910B | | | |
| | | | | HIGH 0.10 | AVG 0.09 | LOW 0.07 | | | | |
| | Treated Water | AA21682 | 3/16/26 | 0.049 | 1/cm | | SM 5910B | | | |
| | Treated Water | AA21725 | 3/26/26 | 0.079 | 1/cm | | SM 5910B | | | |
| | | | | HIGH 0.08 | AVG 0.06 | LOW 0.05 | | | | |

**Monthly Summary of Monitoring
For Surface Water Treatment Regulations**

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: March Year: 2026

Treated Water Turbidities Every Four Hours (NTU)*

| Date | Peak Raw Water Turbidity | Peak Settled Water Turbidity | Midnight to 0400 | 0400 to 0800 | 0800 to Noon | Noon to 1600 | 1600 to 2000 | 2000 to Midnight | Average Treated Water | Minimum Ct. Ratio |
|------|--------------------------|------------------------------|------------------|--------------|--------------|--------------|--------------|------------------|-----------------------|-------------------|
| 1 | | | | | | | | | | |
| 2 | | | | | | | | | | |
| 3 | | | | | | | | | | |
| 4 | | | | | | | | | | |
| 5 | 19.98 | | | | | 0.08 | | | 0.08 | 4.7 |
| 6 | | | | | | | | | | |
| 7 | | | | | | | | | | |
| 8 | | | | | | | | | | |
| 9 | 7.04 | | | | | 0.08 | 0.08 | 0.07 | 0.08 | 4.9 |
| 10 | 1.96 | | 0.08 | 0.07 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 4.9 |
| 11 | 2.08 | | 0.08 | 0.08 | 0.08 | 0.09 | 0.07 | 0.07 | 0.08 | 5.2 |
| 12 | 1.62 | | 0.07 | 0.07 | 0.07 | 0.08 | 0.07 | 0.07 | 0.07 | 4.6 |
| 13 | 1.77 | | 0.08 | 0.07 | 0.07 | 0.08 | 0.07 | 0.07 | 0.07 | 4.8 |
| 14 | 1.44 | | 0.08 | 0.07 | 0.07 | 0.09 | 0.07 | 0.07 | 0.07 | 4.3 |
| 15 | 1.45 | | 0.09 | 0.07 | 0.07 | 0.10 | 0.07 | 0.07 | 0.08 | 5.5 |
| 16 | 1.56 | | 0.11 | 0.07 | 0.07 | 0.08 | 0.07 | 0.07 | 0.08 | 6.1 |
| 17 | 1.56 | | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 5.0 |
| 18 | 1.57 | | | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 4.2 |
| 19 | | | | | | | | | | |
| 20 | | | | | | | | | | |
| 21 | | | | | | | | | | |
| 22 | | | | | | | | | | |
| 23 | | | | | | | | | | |
| 24 | | | | | | | | | | |
| 25 | | | | | | | | | | |
| 26 | 1.91 | | | | | 0.07 | 0.09 | 0.08 | 0.08 | 4.9 |
| 27 | 1.24 | | 0.07 | | 0.08 | 0.08 | 0.11 | 0.08 | 0.08 | 4.2 |
| 28 | | | | | | | | | | |
| 29 | | | | | | | | | | |
| 30 | 2.13 | | | | | 0.07 | 0.07 | 0.08 | 0.08 | 5.2 |
| 31 | 1.21 | | 0.08 | 0.07 | 0.08 | 0.08 | 0.07 | 0.09 | 0.08 | 5.5 |
| Ave. | 3.23 | | | | | | | | 0.07 | 4.2 |

*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 74 No. of Readings ≤ 0.3 NTU: 74

% Readings ≤ 0.3 NTU = [(No. Readings ≤ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are ≤ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = [(Average Raw NTU - Average Effluent NTU) / (Average Raw NTU)] x 100 = 98%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.091

Incidents of turbidity greater than 1.0 NTU

| | | | | |
|------------------|--|--|--|--|
| Date of Incident | | | | |
| Value | | | | |
| Duration | | | | |

Total Number of incidents where turbidity is > 1.0 NTU: 0
 Total Number of incidents where turbidity is > 5.0 NTU: 0
 Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

a. < 2.0 NTU after all events (Y/N)? Y
 b. < 1.0 NTU after 90% of events (Y/N)? Y
 c. < 0.5 NTU after 4 hours (Y/N)? Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

| Date | Which Turbidimeter | Standard used (primary/secondary) | Date | Which Turbidimeter | Standard Used (primary/secondary) |
|------------|--------------------|-----------------------------------|------------|--------------------|-----------------------------------|
| 12/19/2024 | Hach, raw wtr | 0/20 Formazin | 12/19/2024 | Hach, treated | 0/20 Formazin |
| 3/28/2025 | Hach, raw wtr | 0/20 Formazin | 3/28/2025 | Hach, treated | 0/20 Formazin |
| 6/27/2025 | Hach, raw wtr | 0/20 Formazin | 6/27/2025 | Hach, treated | 0/20 Formazin |
| 9/29/2025 | Hach, raw wtr | 0/20 Formazin | 9/29/2025 | Hach, treated | 0/20 Formazin |
| 12/24/2026 | Hach, raw wtr | 0/20 Formazin | 12/24/2026 | Hach, treated | 0/20 Formazin |
| 3/26/2026 | Hach, raw wtr | 0/20 Formazin | 3/26/2026 | Hach, treated | 0/20 Formazin |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Disinfection Process Data

Disinfectant residual type: free chlorine: X combined chlorine: _____ other (specify) _____

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

| | | | | |
|---------------------|--|--|--|--|
| Date of Incident | | | | |
| Duration | | | | |
| Date Dept. Notified | | | | |

Total number of incidents where residual is < 0.2 ppm: 0
 Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? Y

| | |
|---|---|
| No. of distribution system residual samples collected: | 1 |
| No of distribution system samples for HPC only: | |
| Total No. residual and/or HPC samples collected: | 1 |
| No. of samples with no detectable residual and HPC is not measured: | 0 |
| No. of samples with no residual and HPC > 500 CFU/ml: | |
| No. of samples for HPC only and HPC > 500 CFU/ml: | |
| Total No. Samples with no residual and/or HPC > 500 CFU/ml: | 0 |

Compute V where $V = [1 - (\text{Total number of samples with no residual and/or HPC} > 500) / (\text{Total number of residual and/or HPC samples collected})] \times 100 =$ 100%

Meets Standard (i.e V > 95%) (Y/N) Y

**Quarterly Report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines**

System Name: La Honda Water System (CSA #7) System No.: CA4100509

Calendar Year: 2026 Quarter: 1

| 1st Quarter | | | |
|--|-------------------------|------------------------------------|----|
| Month | Number of Samples Taken | Monthly Ave. Chlorine Level (mg/L) | |
| 7/12/2010 | April | 1.10 | |
| | May | 1.16 | |
| | June | 1.09 | |
| | July | 1.48 | |
| | August | 1.63 | |
| | September | 1.70 | |
| | October | 1.29 | |
| | November | 1.32 | |
| | December | 1.06 | |
| | Current Year | January | 11 |
| | | February | 5 |
| | | March | 5 |
| Running Annual Average (RAA): | | 1.22 | |
| Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂) | | Yes | |

| 2nd Quarter | | |
|--|-------------------------|------------------------------------|
| Month | Number of Samples Taken | Monthly Ave. Chlorine Level (mg/L) |
| Previous Year | July | 1.48 |
| | August | 1.63 |
| | September | 1.70 |
| | October | 1.29 |
| | November | 1.32 |
| | December | 1.06 |
| Current Year | January | 0.73 |
| | February | 0.61 |
| | March | 1.47 |
| | April | |
| | May | |
| | June | |
| Running Annual Average (RAA): | | |
| Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂) | | |

| 3rd Quarter | | |
|--|-------------------------|------------------------------------|
| Month | Number of Samples Taken | Monthly Ave. Chlorine Level (mg/L) |
| Previous Yr | October | 1.29 |
| | November | 1.32 |
| | December | 1.06 |
| Current Year | January | 0.73 |
| | February | 0.61 |
| | March | 1.47 |
| | April | |
| | May | |
| | June | |
| | July | |
| | August | |
| | September | |
| Running Annual Average (RAA): | | |
| Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂) | | |

| 4th Quarter | | |
|--|-------------------------|------------------------------------|
| Month | Number of Samples Taken | Monthly Ave. Chlorine Level (mg/L) |
| Current Year | January | 0.73 |
| | February | 0.61 |
| | March | 1.47 |
| | April | |
| | May | |
| | June | |
| | July | |
| | August | |
| | September | |
| | October | |
| | November | |
| | December | |
| Running Annual Average (RAA): | | |
| Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂) | | |

Comments:

Signature: 

Date: 4/10/2026

Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System (CSA #7) System No.: CA4100509 Year: 2026 Quarter: 1

| Year: | 2022 | | | | 2023 | | | | 2024 | | | | 2025 | | | | 2026 | | | |
|----------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| Quarter: | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. |
| Sample Date (month/date): | 3/1 | 6/14 | 9/13 | 12/13 | 3/28 | 6/13 | 9/20 | 12/13 | 3/19 | 6/24 | 9/18 | 12/10 | 3/20 | 6/3 | 9/29 | 12/9 | 3/16 | | | |
| Site 1 | 31.0 | 65.0 | 80.0 | 102.0 | 44.0 | 40.0 | 68.0 | 56.0 | 42.0 | 92.0 | 59.0 | 51.0 | 85.0 | 47.0 | 58.0 | 54.0 | 44.0 | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| Quarterly Average | 31.0 | 65.0 | 80.0 | 102.0 | 44.0 | 40.0 | 68.0 | 56.0 | 42.0 | 92.0 | 59.0 | 51.0 | 85.0 | 47.0 | 58.0 | 54.0 | 44.0 | | | |
| Running Annual Average | 77.7 | 79.8 | 90.2 | 69.5 | 72.8 | 66.5 | 63.5 | 52.0 | 51.5 | 64.5 | 62.3 | 61.0 | 71.8 | 60.5 | 60.3 | 61.0 | 50.8 | | | |
| Meets Standard (80 ug/L)?* | Yes | Yes | No | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | | | |
| Number of Samples Taken | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | | | |

Identify the sample locations in the table below.

| Site | Sample Location |
|------|--------------------------|
| 1 | Old Chlorination Station |
| 2 | |
| 3 | |
| 4 | |
| 5 | |
| 6 | |
| 7 | |
| 8 | |
| 9 | |
| 10 | |
| 11 | |
| 12 | |

Greg W. Brannell

 Signature 4/14/2026
 Date

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

Quarterly HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System System No.: CA4100509 Year: 2026 Quarter: 1

| Year: | 2022 | | | | 2023 | | | | 2024 | | | | 2025 | | | | 2026 | | | |
|----------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| Quarter: | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. | 1st Qtr. | 2nd Qtr. | 3rd Qtr. | 4th Qtr. |
| Sample Date (month/date): | 3/1 | 6/14 | 9/13 | 12/13 | 3/28 | 6/13 | 9/20 | 12/13 | 3/19 | 6/24 | 9/18 | 12/10 | 3/20 | 6/3 | 9/29 | 12/9 | 3/16 | | | |
| Site 1 | 22.0 | 35.0 | 43.0 | 87.0 | 19.0 | 32.0 | 42.0 | 34.0 | 31.0 | 88.0 | 61.0 | 47.0 | 59.0 | 39.0 | 52.0 | 44.0 | 48.0 | | | |
| Site 1 Sample | | | | | | | | | | | | | | | | | | | | |
| Site 3 | | | | | | | | | | | | | | | | | | | | |
| Site 4 | | | | | | | | | | | | | | | | | | | | |
| Site 5 | | | | | | | | | | | | | | | | | | | | |
| Site 6 | | | | | | | | | | | | | | | | | | | | |
| Site 7 | | | | | | | | | | | | | | | | | | | | |
| Site 8 | | | | | | | | | | | | | | | | | | | | |
| Site 9 | | | | | | | | | | | | | | | | | | | | |
| Site 10 | | | | | | | | | | | | | | | | | | | | |
| Site 11 | | | | | | | | | | | | | | | | | | | | |
| Site 12 | | | | | | | | | | | | | | | | | | | | |
| Quarterly Average | 22.0 | 35.0 | 43.0 | 87.0 | 19.0 | 32.0 | 42.0 | 34.0 | 31.0 | 88.0 | 61.0 | 47.0 | 59.0 | 39.0 | 52.0 | 44.0 | 48.0 | | | |
| Running Annual Average | 41.5 | 42.1 | 53.0 | 46.8 | 46.0 | 45.3 | 45.0 | 31.8 | 34.8 | 48.8 | 53.5 | 56.8 | 63.8 | 51.5 | 49.3 | 48.5 | 45.8 | | | |
| Meets Standard (60 ug/L)?* | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | Yes | No | Yes | Yes | Yes | Yes | | | |
| Number of Samples Taken | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | | | |

Identify the sample locations in the table below.

| Site | Sample Location |
|------|--------------------------|
| 1 | Old Chlorination Station |
| 2 | |
| 3 | |
| 4 | |
| 5 | |
| 6 | |
| 7 | |
| 8 | |
| 9 | |
| 10 | |
| 11 | |
| 12 | |

Gregory W. Bassett

Signature _____ Date 4/14/2026

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

State of California
Water Resources Control Board
Division of Drinking Water
Coliform Reporting Form

Date of Report: April 08, 2026

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: March, 2026

System Name: **La Honda Water System**

System Number: **CA4100509**

| Collection Date | Site Name | Analyte | Sample Type | Result | Remarks | Sampler |
|-----------------|-----------------------------------|----------|-------------|--------|------------------|---------------|
| 3/16/2026 | Alpine Creek - Raw Water | Coliform | Other | 185.0 | SM9223B-18 (MPN) | Keefe Brennan |
| 3/16/2026 | Alpine Creek - Raw Water | E. Coli | Other | 38.3 | SM9223B-18 (MPN) | Keefe Brennan |
| 3/16/2026 | APN 083-240-070 (No site address) | COLIFORM | Routine | A | SM9223B-18 | Keefe Brennan |
| 3/16/2026 | APN 083-240-070 (No site address) | E. COLI | Routine | A | SM9223B-18 | Keefe Brennan |

1 = Routine
2 = Repeat
3 = Replacement
4 = Other
P = Present
A = Absent